

**Lakeside Park Water System  
Activity Summary  
November 2008**

**Water Treatment:**

Bacteria sampling.

Plant Maintenance

Tested and exercise emergency power generation system

Responded to various alarms and corrected.

All water produced met safe drinking water standards

Equipment calibration

Order operating supplies

**Water Distribution:**

**Miscellaneous:**

Misc. USA locates

**Administration:**

Submitted October 2008 Monitoring report

**Lakeside Park Water System  
Activity Summary  
December 2008**

**Water Treatment:**

Bacteria sampling.

4<sup>th</sup> Quarter D/DBP sampling

Plant Maintenance

Tested and exercise emergency power generation system

Responded to various alarms and corrected.

All water produced met safe drinking water standards

Equipment calibration

Order operating supplies

**Water Distribution:**

Posted shut-off notices

Shut water off to Block properties

Responded to water leak at Lone Pine Motel

**Miscellaneous:**

Misc. USA locates

Snow removal

**Administration:**

Submitted November 2008 Monitoring report

Attended 4<sup>th</sup> Quarter TWSA Meeting

Reviewed and submitted Source Water Assessment Report

# Lakeside Park Water System Activity Summary January 2009

## **Water Treatment:**

Bacteria sampling.

Plant Maintenance

Tested and exercise emergency power generation system

Responded to various alarms and corrected.

All water produced met safe drinking water standards

Equipment calibration

Order operating supplies

## **Water Distribution:**

Cold water outlet count at 4021 Azure

Reinstated Water Service to old Holiday Lodge

Maintenance Service on Plant Generator

Responded to water leak at Paradise Motel

## **Miscellaneous:**

Misc. USA locates

Snow removal

## **Administration:**

Submitted December 2008 Monitoring report

Submitted 4<sup>th</sup> quarter 2008 D/DBP Report

**Lakeside Park Water System  
Activity Summary  
February 2009**

**Water Treatment:**

Bacteria sampling.

Plant Maintenance

Tested and exercise emergency power generation system

Responded to various alarms and corrected.

All water produced met safe drinking water standards

Equipment calibration

Order operating supplies

Rebuilt Chlorine Pump #4

**Water Distribution:**

Responded to water leak on Greenwood  
Maintenance Service on Beach Generator

**Miscellaneous:**

Misc. USA locates  
Snow removal

**Administration:**

Submitted January 2009 Monitoring report

**Lakeside Park Water System  
Activity Summary  
March 2009**

**Water Treatment:**

Bacteria sampling.

Plant Maintenance

Tested and exercise emergency power generation system

Responded to various alarms and corrected.

All water produced met safe drinking water standards

Equipment calibration

Order operating supplies

Replace Valve Actuator on Filter # 1

Replaced Solids Pump #2 in Backwash Holding Tank

1<sup>st</sup> Quarter D/DBP Sampling

**Water Distribution:**

Replaced Block Heater in Plant Generator

**Miscellaneous:**

Misc. USA locates  
Snow removal

**Administration:**

Submitted February 2009 Monitoring report  
Attended 1<sup>st</sup> Quarter TWSA Meeting