

# **Lakeside Park Water System Activity Summary November 2007**

## **Water Treatment:**

Completed monthly Bacteria sampling

Tested and exercise emergency power generation system

Responded to various alarms and corrected.

Checked Current draws for raw water pumps

No treatment failures occurred during this time period

All water produced met safe drinking water standards

## **Water Distribution:**

Replaced fire hydrants (3 ea) on Sunrise – near Hill St, Manzanita and Popular and Cedar and Popular.

Installed new service connections to the Tradewinds Motel, Stardust and Cedar Lodge.

Completed paving repairs on Cedar over newly installed main line extension.

## **Miscellaneous:**

Misc. USA locates

## **Administration:**

Submitted October 2007 Monitoring report

Submitted 3<sup>rd</sup> Quarter Disinfection By-products Report

Backflow testing requirements notifications mailed

