

Lakeside Park Water System Activity Summary August 2007

Water Treatment:

Completed monthly Bacteria sampling

Tested and exercise emergency power generation system

Responded to various alarms and corrected.

Exterior Plant Maintenance

No treatment failures occurred during this time period

All water produced met safe drinking water standards

Water Distribution:

Continued work in the Project 3 area. Inspected contractor's work when exposing LPA's water lines to insure they are not damaged during excavation. Located and identified water lines on Cedar that were not listed on plans. Made repairs and rerouted lines as necessary.

Resolving water distribution system problems with developer on Cedar.

Cedar Water Main Extension planning and coordination

Cedar Water Main installation

Exercising and cleaning water distribution system main valves

Respond to leak call-out at 4070 Sunrise; found to be property owner's responsibility

Miscellaneous:

Misc. USA locates

Administration:

Submitted August 2007 Monitoring report

Purchase and planning to replace 3 fire hydrants; they are located on Sunrise & Hill, Manzanita & Popular and Cedar & Popular.